



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TVM43249

Issued Date : 16-07-2026

Organization Type : Educational Institutions

Expiry Date : 15-07-2027

Name of the Organization : SWAMY ABEDHANANDHA
VIDHYASHRAM SCHOOL

Address : KADAISIKULAM VILLAGE, MARUTHADU POST,
MELMARUVATHUR SALAI, VANDAVASI

I, SURESH R owner/manager of the SWAMY ABEDHANANDHA VIDHYASHRAM SCHOOL functioning as **Educational Institutions** located at **Maruthadu** in **Tiruvannamalai** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **16-07-2026** to **15-07-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **1500** people/pupils and has **36** urinals and **42** toilets which is proportionate to the number of users as per government norms.
- **11** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00126TVM43249 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TVM43249 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY

TWAD Board, Near New Veeranam Illam, GST road

Phone: 04147 - 227300

Tindivanam - 604 401

twadstlab975@gmail.com

From,
Er. S.Karthikeyan B.E.,
Assistant executive Engineer,
District Water Testing Laboratory,
Tindivanam.



To,
Swami Abhedhanantha School,
Kadaisikulam,
Vandavasi.

Sir,

Lr.No. 919 / DWT / TDM Date: 23.07.2026

Sub: Examination of water sample Report Furnished-Reg.

The Result of analysis for the water samples received vide ref cited is finished below.

Date of Receipt:	08.07.2026	Sample I D No. 919	Union : vandavasi Panchayat : Kadaisikulam Types of Source: Open Well Location: Swami Abhedhanantha School
Date of Testing:	08.07.2026		
District	Villupuram		
BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION			
1. Appearance	-	-	Clear
2. Odour	Agreeable	Agreeable	None
3. Turbidity NT Units	1	5	0
4. Total dissolved Solids mg/L	500	2000	533
5. Electrical Conductivity Micro mho/cm	500	2000	762
II. CHEMICAL EXAMINATION:			
6. pH	6.5-8.5	6.5-8.5	7.64
7. Total Alkalinity. as CaCO ₃ mg/L	200	600	329
8. Total Hardness as CaCO ₃ mg/L	200	600	520
9. Calcium as Ca mg/L	75	200	102
10. Magnesium as Mg mg/L	30	100	97
11. Iron as Fe mg/L	0.3	0.3	0.0
12. Manganese mg/L	0.1	0.1	0.0
13. Free Ammonia as NH ₃ mg/L	0.5	5.0	0.0
14. Nitrite as NO ₂ mg/L	-	-	-
15. Nitrate as NO ₃ mg/L	0	45	8
16. Chloride as Cl mg/L	250	1000	113
17. Fluoride as F mg/L	1.0	1.5	0.0
18. Sulphate as SO ₄ mg/L	200	400	259
19. Phosphate as PO ₄ mg/L	0.5	5.0	0.0
III. BACTERIOLOGICAL EXAMINATION (M.F. Technique)			
Fecal Coliform (100 ml)	0	0	0

Report : The water sample meet requirement of IS:10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters.


Lab Chemist


Assistant executive Engineer
District Water Testing Laboratory,
Tindivanam